

(Note: Edit these specifications to fit your project detail. Samples and estimating examples are available through www.SnoGuard.com, e-mail sales@SnoGuard.com or call 708.485-6272.)

Section 07 72 53 Roof Accessories – Snow Guards

(Gough SnoGuard Type SGAR-SLS Specification Sheet for Retrofit Slate Roofing)

PART 1 – GENERAL REQUIREMENTS

1.01 SUMMARY

A. DESCRIPTION OF WORK

1. Install Gough SnoGuard Type SGAR-SLS snow guards for slate roofs.
2. Assure proper positioning of snow guards retrofitted on pre-existing installed slate roof.
3. Choice of fastener not necessary. This SG has built-in adjustable slotted strap for mechanical attachment.

B. RELATED SECTIONS

1. Section 07600 / Flashing and Sheet Metal / MasterFormat™ 2004 07 60 00
2. Section 07310 / Roofing Shingles / MasterFormat™ 2004 07 31 00
3. Section 07710 / Prefabricated Roof Specialties / 2004
4. Division 7: Thermal and Moisture Protection.

1.02 SUBMITTALS

- A. PRODUCT DATA: Submit manufacturer's product data & installation instructions.
- B. SHOP DRAWINGS: If not clearly shown on project drawings, submit roof drawing showing locations of all Gough SnoGuard Type SGAR-SLS snow guards and attachment spacing.
- C. SAMPLES: Submit sample of one Type SGAR-SLS snow guard as requested.

1.03 QUALITY ASSURANCE:

- A. INSTALLER: Installer is to be experienced in the installation of specified roofing material and snow guards for not less than 5 years in the area of the project.
- B. FASTENERS: Not necessary. Use built-in adjustable slotted strap for mechanical attachment.
- C. CODE COMPLIANCE: Comply with all applicable local, state, and national building codes, as well as OSHA regulations.
- D. STORAGE: Boxes containing Gough SnoGuards should be stored in a dry place until ready for use.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. Gough SnoGuards, 4133 Du Bois Blvd., Brookfield, IL 60513-1809, voice (708) 485-6272, fax (708) 485-6273, e-mail: Sales@SnoGuard.com, Web Site: www.SnoGuard.com

2.2 MATERIAL

- A. 24 oz. cold rolled copper
- B. With double pedestal

2.3 FINISH

- A. Copper

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Substrate: Inspect roof system to be properly attached and installed to withstand additional loading incurred. Notify General Contractor of any deficiencies before installing Gough SnoGuards.

3.02 INSTALLATION

- A. Comply with architectural drawings for placement & Manufacturer's instructions for installation. Contact Manufacturer for sample layouts if needed.¹